

10. 製品認証書

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ СЕРТИФИКАТ ◆ CERTIFICATE ◆ CERTIFICAT



Product Service

CERTIFICATE

No. Z2 070321 0097 Rev. 53

Holder of Certificate: **Trina Solar Co., Ltd.**
No. 2 TianHe Road, Trina PV Industrial Park
New District
213031 Changzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono & Poly Crystalline Silicon Photovoltaic (PV) Module(s)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290170581768

Valid until: 2029-03-20

Date, 2024-03-22

(Zhulin Zhang)



CERTIFICATE

No. Z2 070321 0097 Rev. 53

TSM-xxxNEG9M5C.26(xxx=305-335, in steps of 5).

56 cells:

TSM-xxxNEG9M4C.26(xxx=265-290, in steps of 5).

mono series with 182.0 x 70.0 (mm) N type 1/3 cutting MBB bifacial cell:

144 cells:

TSM-xxxNEG9RC.20, TSM-xxxNEG9RC.25,
TSM-xxxNEG9RC.28, TSM-xxxNEG9RC.27,
TSM-xxxNEG9RC.29, TSM-xxxNEG9RC.B0,
TSM-xxxNEG9RC.B5, TSM-xxxNEG9RC.B8,
TSM-xxxNEG9RC.B7, TSM-xxxNEG9RC.B9,
(xxx=375-460, in steps of 5).

mono series with 182.0 x 70.0 (mm) N type 1/3 cutting MBB bifacial cell:

(Module Type for rear side with white EVA or Glass white)

144 cells:

TSM-xxxNEG9R.20, TSM-xxxNEG9R.25,
TSM-xxxNEG9R.28, TSM-xxxNEG9R.27,
TSM-xxxNEG9R.29, TSM-xxxNEG9R.B0,
TSM-xxxNEG9R.B5, TSM-xxxNEG9R.B8,
TSM-xxxNEG9R.B7, TSM-xxxNEG9R.B9,
(xxx=375-460, in steps of 5).

mono series with 182.0 x 105.0 (mm) half cutting N type MBB bifacial cell:

132 cells:

TSM-xxxNEG19RC.20, TSM-xxxNEG19RC.25,
TSM-xxxNEG19RC.27, TSM-xxxNEG19RC.28,
TSM-xxxNEG19RC.29, TSM-xxxNEG19RC.70,
TSM-xxxNEG19RC.80 (xxx=525-620, in steps of 5).

mono series with 182.0 x 105.0 (mm) half cutting N type MBB bifacial cell:

(Module Type for rear side with white EVA or Glass white)

132 cells:

TSM-xxxNEG19R.20, TSM-xxxNEG19R.25,
TSM-xxxNEG19R.27, TSM-xxxNEG19R.28,
TSM-xxxNEG19R.29, (xxx=525-620, in steps of 5).

108 cells

TSM-xxxNEG18R.20, TSM-xxxNEG18R.25,
TSM-xxxNEG18R.27, TSM-xxxNEG18R.28,
TSM-xxxNEG18R.29, (xxx=470-505, in steps of 5)

mono series with 182.0 x 91.0 (mm) or 182.2 x 91.875 (mm) half cutting N type MBB bifacial cell:

144 cells:

TSM-xxxNEG18C.20, TSM-xxxNEG18C.25,
TSM-xxxNEG18C.27, TSM-xxxNEG18C.28,
TSM-xxxNEG18C.29, (xxx=555-595, in steps of 5)

mono series with 182.2 x 91.875(mm) half cutting N type MBB bifacial cell:

156 cells:

TSM-xxxNEG20MC.20, TSM-xxxNEG20MC.25,
TSM-xxxNEG20MC.27, TSM-xxxNEG20MC.28,
TSM-xxxNEG20MC.29, (xxx=600-635, in steps of 5)



Product Service

CERTIFICATE

No. Z2 070321 0097 Rev. 53

mono series with 210.0 x 105.0 (mm) half cutting N type MBB bifacial cell:
 132 cells:
 TSM-xxxNEG21C.20S (xxx=635-690, in steps of 5)

mono series with 182.0 x 105.0 (mm) half cutting N type MBB bifacial cell:
 132 cells:
 TSM-xxxNEG19RC.20S (xxx=565-595, in steps of 5)

mono series with 182.0 x 70.0 (mm) N type 1/3 cutting MBB bifacial cell:
 (Module Type for rear side with white EVA or Glass white)
 144 cells:
 TSM-xxxNEG9R.20S, TSM-xxxNEG9R.28S (xxx=395-445, in steps of 5)

xxx stands for rated output power at STC

Parameters:

Construction:	Framed and Frameless with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL 790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016
- EN IEC 61730-1:2018
- EN IEC 61730-2:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018/AC:2018-06